

Washington Fire Department
Mark Chenoweth, Fire
Marshal/Building Code Official
215 East Washington Street
Washington, Iowa 52353
(319) 460-0132 Cell Phone
mchenoweth@washingtioniowa.gov



City of Washington
215 East Washington Street
Washington, Iowa 52353
(319) 653-6584 Phone
(319) 653-5273 Fax

Mobile Food Vehicle

Fire Safety Inspection

Name _____ Inspection Date _____

Business Name _____ Phone Number _____

Email _____

Type I Hood with fire suppression Yes/No/NA (CIRCLE ONE) Hood Clean? Yes/No/NA (CIRCLE ONE)

Class K Fire Ext. Yes/No/NA (CIRCLE ONE) 2A:10BC (min.) Fire Ext. Yes/No (CIRCLE ONE)

Service/Inspection Tags: Hood _____ (DATE) Suppression System _____ (DATE)

Class K _____ (DATE) 2A:10BC _____ (DATE) Other _____ (DATE)

Gas Type: (CIRCLE ONE) LP (Propane) CNG (Compressed Natural Gas) *must comply with NFPA 52*

Tank size _____ lbs. No. of Tanks _____ *200 lbs. propane aggregate (max)*

Gas Tanks Fully Restrained/Protected Yes /No (CIRCLE ONE)

Piping/Connections Secured/Protected Yes /No (CIRCLE ONE)

Cooking Appliances secured in place? Yes / No (CIRCLE ONE)

Carbon Monoxide detector installed Yes /No (CIRCLE ONE) Manufacture Date _____

Inspector _____ Inspector's Signature _____

Fire Chief _____ Signature _____ Date _____

Continued on next page...

