



FIELD OBSERVATION #03

Project: Washington City Hall & Police Station
Washington, Iowa

Date: December 12, 2019
Time: 3:30 p.m.

Weather: Overcast
Temperature: 48°

Present: Kristofer Orth Farnsworth Group, formerly Design Alliance

The purpose of this field observation was to review construction progress made to date.

1. Contractors were in the process of pouring and finishing the footings, foundation walls & stoop frost walls at Vestibule [131].
2. At the east and south sides of the building, the remainder of the metal wall panels have been removed. Framing, sheathing, and air barrier have been installed. Window openings have been covered with polyethylene sheeting.
3. A temporary door has been installed for access at Door (147). A second temporary access has been installed at the south window of City Clerk [149].
4. Contractors are working on installation of the woven fabric insulation system. The south bay fabric is nearly completed.
5. The metal banding straps running north & south have been installed at the other three bays.
6. Contractors are utilizing two of the existing gas fired unit heaters for temporary heat.
7. A new electrical panel has been installed next to Door (099).
8. Woven fabric insulation system metal straps have been installed in Electric [099].

Respectfully Submitted,

FARNSWORTH GROUP, INC. formerly Design Alliance, Inc.

Kristofer J. Orth, AIA
KJO:bv

Cc: Brent Hinson, City of Washington (for distribution)
John Bushong, Bushong Construction
Mike Fleming, Bushong Construction
Tyler Luttenegger PE, MODUS
Steve Soupir PE, Fox Engineering
Job Book

Enclosures





