

Washington Fire Department
Brendan Delong, Fire Chief
215 East Washington Street
Washington, Iowa 52353
(319) 653-2239 Phone
firedept@washingtioniowa.gov



City of Washington
215 East Washington Street
Washington, Iowa 52353
(319) 653-6584 Phone
(319) 653-5273 Fax

Mobile Food Vehicle

Fire Safety Inspection

Name _____ Inspection Date _____

Business Name _____ Phone Number _____

Type I Hood with fire suppression Yes/No/NA (CIRCLE ONE) Hood Clean? Yes/No/NA (CIRCLE ONE)

Class K Fire Ext. Yes/No/NA (CIRCLE ONE) 2A:10BC (min.) Fire Ext. Yes/No (CIRCLE ONE)

Service/Inspection Tags: Hood _____ (DATE) Suppression System _____ (DATE)

Class K _____ (DATE) 2A:10BC _____ (DATE) Other _____ (DATE)

Gas Type: (CIRCLE ONE) LP (Propane) CNG (Compressed Natural Gas) must comply with NFPA 52

Tank size _____ lbs. No. of Tanks _____ 200 lbs. propane aggregate (max)

Gas Tanks Fully Restrained/Protected Yes /No (CIRCLE ONE)

Piping/Connections Secured/Protected Yes /No (CIRCLE ONE)

Cooking Appliances secured in place? Yes / No (CIRCLE ONE)

Carbon Monoxide detector installed Yes /No (CIRCLE ONE) Manufacture Date _____

Generator: Make _____ Output _____ kw Free from defects? Yes / No (CIRCLE ONE)

Inspector _____ Inspector Signature _____

Fire Chief _____ Signature _____ Date _____

